

August 11, 2005

CERTIFIED RETURN RECEIPT xxx xxx xxx

Mr. Randy Shuman
CTI-SSI Food Services, LLC
P. O. Box 700
Caldwell, Idaho 83606-0700

**RE: CTI-SSI Food Services, LLC Wastewater Land Application Permit LA-000095-02
Draft Permit Modification, Appendix "C"**

Dear Mr. Shuman:

Enclosed for your review and comment is a draft permit modification "Appendix C" to your land application permit LA-000095-02. This draft permit modification provides for revised non-growing season application rates. Comments on this draft modification are due no later than August 31, 2005.

Also enclosed is the staff analysis used to prepare this draft permit modification.

If you have any questions or need further information, please call me at (208) 373-0252 or contact Paul Wakagawa at (208) 373-0244 or via email at paul.wakagawa@deq.idaho.gov

Sincerely,

Charles W. Ariss, P.E.
Regional Engineering Manager

Enclosures: Draft permit modification and staff analysis

cc: Michael R. McGown, Administrator, Boise Regional Office
Charles Brockway, Jr., P.E., Brockway Engineering, 2016 North Washington St., Twin Falls 83301
Paul Wakagawa, P.E., Boise Regional Office
Richard Huddleston, P.E., State Water Quality Office
Tressa Nicholas, Boise Regional Office
SO WLAP File LA-000095-02
BRO file 17.1, CTI-SSI, LA-000095-02, Reading File

D R A F T
August 2005

**MODIFICATION OF LAND APPLICATION PERMIT
APPENDIX "C" TO PERMIT NO. LA-000095-02**

Permittee Name: CTI-SSI Food Services, LLC

Effective Date: _____

Complete Description of Modification

1. Section F., Permit Limits and Conditions, Page 9.

Revise the Non-Growing Season (NGS) maximum hydraulic loading rates as follows:

Hydraulic Management Unit	Field	Maximum Hydraulic Loading Rate, Million Gallons	Previous Limit, Million Gallons
MU-009501	CP-N	15.9	15.1
MU-009502	CP-S	15.9	15.1
MU-009503 ^a	F-N	4.9	0
MU-009505	Pivot Corners	7.1	0
MU-009506	CP-17B	12.0	11.5
	Total:	55.8	41.7

- a. Land application of wastewater on Field F-N is reserved for emergency use to prevent exceeding NGS hydraulic limits on the other fields. CTI-SSI shall notify DEQ at least 7 days prior to applying wastewater on Field F-N.

2. Section G., Monitoring Requirements, Page 13.

Revise the frequency for monitoring dissolved oxygen in lagoon LA-009501 from "Daily" to "Daily, when in use for wastewater storage".

3. Section G., Monitoring Requirements, Page 13

Revise the frequency for sampling supplemental irrigation water from "May and Oct" to "Twice, near the start and near the end of the irrigation water supply season".

The modification described above and referred to as Appendix "C" is hereby approved. This appendix to the permit is incorporated into and constitutes a part of Permit No. LA-000095-02. This appendix must be attached to the permit. The permit is incomplete and unlawful under the Wastewater-Land Application Permit Regulations without this appendix attached.

Signed,

MICHAEL R. MCGOWN, ADMINISTRATOR
BOISE REGIONAL OFFICE
DEPARTMENT OF ENVIRONMENTAL QUALITY

DATE